



City of Rockville
111 Maryland Avenue
Rockville, Maryland

**INVITATION FOR BID #31-13
FURNISH AND INSTALL PLAYGROUND EQUIPMENT AT
DAVID SKULL PARK AND MONTROSE COMMUNITY CENTER PARK**

ADDENDUM NO. 1

DATE: April 23, 2013

To All Bidders:

Contractors submitting bids for the above named project shall take note of the following changes, additions, deletions and clarifications to the Bid Documents, which shall become a part of and have precedence over anything contrarily shown or described in the Bid Documents.

Note: Pre-Bid Meeting : A pre-bid meeting **was** held at the City of Rockville Parks and Facilities Training Room, 14625 Rothgeb Drive, Rockville, MD 20851 on Thursday, April 18, 2013 at 10am. While attendance was not mandatory, all bidders were strongly urged to attend.

The following additional questions were asked at the Pre-Bid Meeting that required follow-up:

- 1. Is there a staging area at one or both job sites?**
There is minimal, non-residential, space for job on-site storage and so on-site storage is not allowed. It is possible to place a locked storage container off-site at 14625 Rothgeb Drive, Rockville, MD, upper parking lot, for a period of no more than four (4) weeks.
- 2. Regarding the 3-D Color Drawing for Montrose Community Center Park, it shows a 3 inch OD "Tee" style swing, is this correct?**
No – the 2-D drawing and the written specifications have the correct information of a 5 inch arched style swing.
- 3. The Pre-Bid Meeting Attendee List has been posted on the City's web site:**
<http://www.rockvillemd.gov/business/bids.htm> (scroll down to IFB #31-13)
- 4. Montrose Community Center work cannot begin until August 1, 2013. When does it have to be completed by?**
The work needs to be completed by August 31, 2013.
- 5. Exhibit D calls for a 50 gallon trash receptacle. Do you really want a 50 gallon size?**
No, the trash receptacle should be Wabash Valley, Item #FR500, Brand Name or Equal, 32 gallon, with liner, and side opening access for trash removal.

6. At the pre-bid, information concerning new signage standard was passed out – could you please provide that information.

All Bidders must comply with ASTM F1487-11, including:

- 14.2.1 Information message communicating age appropriateness as determined by the manufacturer/designer.
- 14.2.2 Information message communicating, at a minimum, supervision recommendation.
- 14.2.3 Warning message communicating the removal of helmets, drawstrings or accessories around the neck which are all known to create head entrapment or entanglement hazards.
- 14.2.4 Warning message communicating hot play surfaces and/or ground level protective surfacing, when applicable. These surfaces are known to reach temperatures high enough to cause serious burns to children generally less than four years of age but because of the many variables effecting how and when a surface becomes a safety concern, it was not possible to find a one-size-fits-all approach that the subcommittee could agree upon.
- 14.2.5 Warning message communicating the hazard of play equipment located over hard surfaces, when applicable. This warning message is no longer required to be plastered on each and every piece of free standing equipment.
- 14.3 *Specification for all warning signs or labels, or both:*
- 14.3.1 Specification for all warning signs or labels, or both should conform to ANSI Z535.1 and either ANSI Z535.2 or ANSI Z535.4 in the following areas: legibility, type of lettering, clarity of message and symbol, color specifications and word message and visibility.
- 14.3.2 *Durability for the Labels or Signs* - The labels or signs should be durable and conform to UL 969.
- 14.3.3 It has been and continues to be the responsibility of the owner/operator to replace signs or labels, or both, should they become illegible, destroyed or removed.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

ISSUED BY:

PAT RYAN
BUYER II, April 23, 2013

ACKNOWLEDGE RECEIPT OF ADDENDUM NO. 1 BY SIGNING BELOW AND RETURNING A COPY OF THE ADDENDUM WITH YOUR PROPOSAL.

NAME OF FIRM: _____

AUTHORIZED SIGNATURE: _____

DATE: _____

BID DUE DATE: (UNCHANGED): 2PM, TUESDAY, APRIL 30, 2013